



ALLEGHENY COUNTY SANITARY AUTHORITY

Members of the Board

Corey O'Connor
Chair Person

Harry Readshaw
Sylvia C. Wilson
Shannah Tharp-Gilliam, Ph.D.
Jack Shea
John Weinstein

April 4th, 2022

CONTRACT NO. 1759 G, E, H, P

ENVIRONMENTAL COMPLIANCE FACILITY

ADDENDUM NO. 3

Arietta Scott Williams
Executive Director

Douglas A. Jackson, P.E.
*Director
Operations & Maintenance*

Michelle M. Buys, P.E.
*Director
Environmental Compliance*

Kimberly N. Kennedy, P.E.
*Director
Engineering & Construction*

Karen Fantoni, CPA, CGMA
*Director
Finance*

Michael Lichte, P.E.
*Director
Regional Conveyance*

Jeanne K. Clark
*Director
Governmental Affairs*

Joseph Vallarian
*Director
Communications*

Julie Motley-Williams
*Director
Administration*

All bidders bidding Contract No. 1759 G, E, H, P shall read and take note of this Addendum No. 3. The Contract Documents for **Contract No. 1759 G, E, H, P – Environmental Compliance Facility** are hereby revised and/or clarified as stated below.

Acknowledgement of Contract No. 1759 G, E, H, P; Addendum No. 3

The Acknowledgement attached to Addendum No. 3 is to be signed and returned immediately via email to **Kathleen Uniatowski** at contract.clerks@alcosan.org and acknowledged with the Bidder's Proposal.

Kimberly Kennedy, P.E.
Director – Engineering and Construction

**ACKNOWLEDGEMENT OF
CONTRACT NO. 1759 G, E, H, P – ENVIRONMENTAL COMPLIANCE
FACILITY**

ADDENDUM NUMBER 3

FIRM NAME: _____

SIGNATURE: _____

TITLE: _____

DATE: _____

April 4th, 2022

CONTRACT NO. 1759 G, E, H, P

ENVIRONMENTAL COMPLIANCE FACILITY

ADDENDUM NO. 3

April 4th, 2022

CONTRACT NO. 1759 G, E, H, P

ENVIRONMENTAL COMPLIANCE FACILITY

ADDENDUM NO. 3

A. Contract Documents – Volume 1

1. Article 2.04:
 - a) Bid Opening Date is changed to Thursday, June 30th, 2022
2. Article 2.11:
 - a) The number of days to submit questions before Bid Opening is changed from 20 to 22.

B. Contract Specifications – Volume 2

1. 07 42 13.13-Metal Wall Panels: Revised and Reissued due to numerous edits

C. Contract Specifications – Volume 3

1. 23 31 13-Metal Ducts
 - a) Section 3.12.D.4, ADD: *Applies to Corrosive Exhaust Air (C-EA) associated with EFF006-220.*
 - b) Section 3.12.A.3, ADD: *All exposed ducts in occupied areas must be 316 Stainless Steel.*
 - c) Section 3.12.F: Remove entire section.
2. 26 09 23- Lighting Control Devices
 - a) Section 3.4.B, ADD: *All lighting control cables inside lab spaces are to be installed in conduit. Lighting control cables in all other spaces concealed above ceiling or behind wall are allowed to be installed without conduit. Cables are to be plenum rated. Any lighting control cable in open or exposed ceiling or wall is to be installed in conduit.*

D. Contract Drawings

1. Drawing 220-ESL-02 ELECTRICAL ONE LINE DIAGRAM, Detail 1
 - a) Replaced the fire alarm conduit annotation “3/4” RGS CONDUIT (TYPICAL ALL FIRE ALARM WIRING)” with “3/4” EMT CONDUIT (TYPICAL ALL FIRE ALARM WIRING EXCEPT PROVIDE RIGID ALUMINUM CONDUITS IN LABORATORY SPACES)”.

E. Questions

None

F. Clarifications

1. The Bid Opening has been moved to Thursday, June 30th
2. The last day to submit questions on the contract is Tuesday, June 7th.
3. The last day a site visit can be scheduled is Thursday, June 2nd.

G. Attachments

Contract Documents:

None

Specifications:

17 42 13.13: Metal Wall Panels

Drawings:

220-ESL-02 ELECTRICAL ONE LINE DIAGRAM

Pre-Bid Documents:

None

Other:

None

* * * * * END OF ADDENDUM NO. 3 * * * * *